

## Building Safety Certificate

Certified that the building of "Angel,s Public School, Chugan, Purana Bazar, Tehsil SunderNagar" Distt. Mandi H.P. has been constructed as per approved plan and a design as per IS code.

Authorized signatory

"Angel,s Public School, Chugan, Purana Bazar, Tehsil SunderNagar" Distt. Mandi H.P.

Certified that the building of "Angel,s Public School, Chugan, Purana Bazar, Tehsil SunderNagar" Distt. Mandi H.P. has been got inspected through Assistant Engineer, Suket Sub-Division, H.P.P.W.D. Suket along with Junior Engineer Bharjwanno Section on 27.12.2022 and found that the building of Block-A consists of two storeys with load bearing structure, bricks masonry works & Block-B consists in single storey with brick masonry and R.C.C. slab. Public Works Department has never supervised this building during construction at any stage. No detailed structural analysis and drawing in seismic and non-seismic condition are available/were provided to check the safety of building. Foundation depth, quality and quantity of material used & cement concrete ratio used is not known to HP.PWD. However Presently by visual inspection the said building seems safe for running the School for the academic session 2023-24 in normal conditions except in case of natural calamities i.e. earth quake, cloud burst, flood, unequal settlement etc. No further construction should be raised on this building.

Executive Engineer  
Sunder Nagar Division  
HPPWD Sunder Nagar

No. PW-SNR-WA-(B-15) Building-2022- 18419-20 Dated:- 29-12-22

Copy to the "Angel,s Public School, Chugan, Purana Bazar, Tehsil SunderNagar" Distt. Mandi H.P. Distt. Mandi H.P.

Copy to the Assistant Engineer, Suket Sub-Division, HP.PWD, Suket for information and necessary action. This is w.r.t. his office letter No. 1711 dated 27.12.2022.

Executive Engineer  
Sunder Nagar Division  
HPPWD Sunder Nagar